



# Dual Channel Temperature Sensor and Overtemperature Alarm

## ADT7482

### FEATURES

- 1 local and 2 remote temperature sensors
- 0.25°C resolution/1°C accuracy on remote channels
- 1°C resolution/1°C accuracy on local channel
- Automatically cancels up to 1.5 kΩ (typ) of resistance in series with the remote sensors
- Extended, switchable temperature measurement range 0°C to +127°C (default) or -55°C to +150°C
- 2-wire SMBus serial interface with SMBus alert support
- Programmable overtemperature/undertemperature limits
- Offset registers for system calibration
- Up to 2 overtemperature fail-safe THERM outputs
- Small, 10-lead MSOP package
- 240 μA operating current, 5 μA standby current

### APPLICATIONS

- Desktop and notebook computers
- Industrial controllers
- Smart batteries
- Automotive
- Embedded systems
- Burn-in applications
- Instrumentation

### GENERAL DESCRIPTION

The ADT7482<sup>1</sup> is a three-channel digital thermometer and undertemperature/overtemperature alarm for PCs and thermal management systems. It can measure the temperature in two remote locations, such as in the remote thermal diode in a CPU or GPU, or using a discrete diode connected transistor. This device also measures its own ambient temperature.

One feature of the ADT7482 is series resistance cancellation where up to 1.5 kΩ (typical) of resistance in series with each of the temperature monitoring diodes can be automatically cancelled from the temperature result, allowing noise filtering. The temperature of the remote thermal diodes and ambient temperature can be measured accurate to ±1°C. The temperature measurement range, which defaults to 0°C to 127°C, can be switched to a wider measurement range of from -55°C to +150°C.

The ADT7482 communicates over a 2-wire serial interface compatible with system management bus (SMBus) standards. The default address of the ADT7482 is 0x4C. An ALERT output signals when the on-chip or remote temperature is outside the programmed limits. The THERM output is a comparator output that allows on/off control of a cooling fan. The ALERT output can be reconfigured as a second THERM output if required.

<sup>1</sup> Protected by U.S. Patents 5,195,827, 5,867,012, 5,982,221, 6,097,239, 6,133,753, 6,169,442, 7,010,440, other patents pending.

### FUNCTIONAL BLOCK DIAGRAM




Figure 1.

1001



# ADT7482

## TABLE OF CONTENTS

|                                                  |    |                                       |    |
|--------------------------------------------------|----|---------------------------------------|----|
| Features .....                                   | 1  | Temperature Value Registers .....     | 12 |
| Applications .....                               | 1  | Conversion Rate Register .....        | 13 |
| General Description .....                        | 1  | Limit Registers .....                 | 13 |
| Functional Block Diagram .....                   | 1  | Status Registers .....                | 14 |
| Revision History .....                           | 2  | Offset Register .....                 | 14 |
| Specifications.....                              | 3  | One-Shot Register .....               | 15 |
| Timing Specifications .....                      | 4  | Consecutive ALERT Register .....      | 15 |
| Absolute Maximum Ratings.....                    | 5  | Serial Bus Interface.....             | 17 |
| Thermal Resistance .....                         | 5  | Addressing the Device .....           | 17 |
| ESD Caution.....                                 | 5  | ALERT Output.....                     | 19 |
| Pin Configuration and Function Descriptions..... | 6  | Low Power Standby Mode.....           | 19 |
| Typical Performance Characteristics .....        | 7  | Sensor Fault Detection .....          | 19 |
| Theory of Operation .....                        | 9  | Interrupt System.....                 | 19 |
| Series Resistance Cancellation.....              | 9  | Applications Information .....        | 22 |
| Temperature Measurement Method .....             | 9  | Noise Filtering.....                  | 22 |
| Temperature Measurement Results.....             | 10 | Factors Affecting Diode Accuracy..... | 22 |
| Temperature Measurement Range .....              | 10 | Thermal Inertia and Self-Heating..... | 22 |
| Temperature Data Format .....                    | 11 | Layout Considerations.....            | 23 |
| Registers .....                                  | 12 | Application Circuit.....              | 23 |
| Address Pointer Register .....                   | 12 | Outline Dimensions .....              | 24 |
| Configuration Registers.....                     | 12 | Ordering Guide .....                  | 24 |

## REVISION HISTORY

6/06—Revision 0: Initial Version

## SPECIFICATIONS

$T_A = -40^{\circ}\text{C}$  to  $+120^{\circ}\text{C}$ ,  $V_{DD} = 3\text{ V}$  to  $3.6\text{ V}$ , unless otherwise noted.

**Table 1.**

| Parameter                                               | Min | Typ  | Max       | Unit               | Test Conditions                                                                                                       |
|---------------------------------------------------------|-----|------|-----------|--------------------|-----------------------------------------------------------------------------------------------------------------------|
| <b>POWER SUPPLY</b>                                     |     |      |           |                    |                                                                                                                       |
| Supply Voltage, $V_{DD}$                                | 3.0 | 3.30 | 3.6       | V                  |                                                                                                                       |
| Average Operating Supply Current, $I_{DD}$              |     | 240  | 350       | $\mu\text{A}$      | 0.0625 conversions/sec rate <sup>1</sup>                                                                              |
|                                                         |     | 5    | 30        | $\mu\text{A}$      | Standby mode                                                                                                          |
| Undervoltage Lockout Threshold                          |     | 2.55 |           | V                  | $V_{DD}$ input, disables ADC, rising edge                                                                             |
| Power-On Reset Threshold                                | 1   |      | 2.5       | V                  |                                                                                                                       |
| <b>TEMPERATURE-TO-DIGITAL CONVERTER</b>                 |     |      |           |                    |                                                                                                                       |
| Local Sensor Accuracy                                   |     |      | $\pm 1$   | $^{\circ}\text{C}$ | $0^{\circ}\text{C} \leq T_A \leq +70^{\circ}\text{C}$                                                                 |
|                                                         |     |      | $\pm 1.5$ | $^{\circ}\text{C}$ | $0^{\circ}\text{C} \leq T_A \leq +85^{\circ}\text{C}$                                                                 |
|                                                         |     |      | $\pm 2.5$ | $^{\circ}\text{C}$ | $-40^{\circ}\text{C} \leq T_A \leq +100^{\circ}\text{C}$                                                              |
| Resolution                                              |     | 1    |           | $^{\circ}\text{C}$ |                                                                                                                       |
| Remote Diode Sensor Accuracy                            |     |      | $\pm 1$   | $^{\circ}\text{C}$ | $0^{\circ}\text{C} \leq T_A \leq +70^{\circ}\text{C}$ , $-55^{\circ}\text{C} \leq T_D^2 \leq +150^{\circ}\text{C}$    |
|                                                         |     |      | $\pm 1.5$ | $^{\circ}\text{C}$ | $0^{\circ}\text{C} \leq T_A \leq +85^{\circ}\text{C}$ , $-55^{\circ}\text{C} \leq T_D^2 \leq +150^{\circ}\text{C}$    |
|                                                         |     |      | $\pm 2.5$ | $^{\circ}\text{C}$ | $-40^{\circ}\text{C} \leq T_A \leq +100^{\circ}\text{C}$ , $-55^{\circ}\text{C} \leq T_D^2 \leq +150^{\circ}\text{C}$ |
| Resolution                                              |     | 0.25 |           | $^{\circ}\text{C}$ |                                                                                                                       |
| Remote Sensor Source Current                            |     | 220  |           | $\mu\text{A}$      | High level <sup>3</sup>                                                                                               |
|                                                         |     | 82   |           | $\mu\text{A}$      | Mid level <sup>3</sup>                                                                                                |
|                                                         |     | 13.5 |           | $\mu\text{A}$      | Low level <sup>2</sup>                                                                                                |
| Maximum Series Resistance Cancelled                     |     | 1.5  |           | $\text{k}\Omega$   | Resistance split evenly on D+ and D– lines                                                                            |
| Conversion Time                                         |     | 71   | 93        | ms                 | From stop bit to conversion complete (all channels) one-shot mode with averaging switched on                          |
|                                                         |     | 11.5 | 15        | ms                 | One-shot mode with averaging off (that is, conversion rate = 16, 32, or 64 conversions per second)                    |
| <b>OPEN-DRAIN DIGITAL OUTPUTS (THERM, ALERT/THERM2)</b> |     |      |           |                    |                                                                                                                       |
| Output Low Voltage, $V_{OL}$                            |     |      | 0.4       | V                  | $I_{OUT} = -6.0\text{ mA}$                                                                                            |
| High Level Output Leakage Current, $I_{OH}$             |     | 0.1  | 1         | $\mu\text{A}$      | $V_{OUT} = V_{DD}$                                                                                                    |
| <b>SMBus INTERFACE<sup>3, 4</sup></b>                   |     |      |           |                    |                                                                                                                       |
| Logic Input High Voltage, $V_{IH}$<br>SCLK, SDATA       | 2.1 |      |           | V                  |                                                                                                                       |
| Logic Input Low Voltage, $V_{IL}$<br>SCLK, SDATA        |     |      | 0.8       | V                  |                                                                                                                       |
| Hysteresis                                              |     | 500  |           | mV                 |                                                                                                                       |
| SDA Output Low Voltage, $V_{OL}$                        |     |      | 0.4       | V                  | $I_{OUT} = -6.0\text{ mA}$                                                                                            |
| Logic Input Current, $I_{IH}$ , $I_{IL}$                | –1  |      | +1        | $\mu\text{A}$      |                                                                                                                       |
| SMBus Input Capacitance, SCLK, SDATA                    |     | 5    |           | pF                 |                                                                                                                       |
| SMBus Clock Frequency                                   |     |      | 400       | kHz                |                                                                                                                       |
| SMBus Timeout <sup>5</sup>                              |     | 25   | 64        | ms                 | User programmable                                                                                                     |
| SCLK Falling Edge to SDATA Valid Time                   |     |      | 1         | $\mu\text{s}$      | Master clocking in data                                                                                               |

<sup>1</sup> See Table 11 for conversion rates.

<sup>2</sup> Guaranteed by characterization, but not production tested.

<sup>3</sup> Guaranteed by design, but not production tested.

<sup>4</sup> See the Timing Specifications section for more information.

<sup>5</sup> Disabled by default. For details on enabling the SMBus, see the Serial Bus Interface section.

# ADT7482

## TIMING SPECIFICATIONS

Table 2. SMBus Timing Specifications<sup>1</sup>

| Parameter                         | Limit at T <sub>MIN</sub> , T <sub>MAX</sub> | Unit    | Description                                      |
|-----------------------------------|----------------------------------------------|---------|--------------------------------------------------|
| f <sub>SCLK</sub>                 | 400                                          | kHz max |                                                  |
| t <sub>LOW</sub>                  | 1.3                                          | μs min  | Clock low period, between 10% points.            |
| t <sub>HIGH</sub>                 | 0.6                                          | μs min  | Clock high period, between 90% points.           |
| t <sub>R</sub>                    | 300                                          | ns max  | Clock/data rise time.                            |
| t <sub>F</sub>                    | 300                                          | ns max  | Clock/data fall time.                            |
| t <sub>SU; STA</sub>              | 600                                          | ns min  | Start condition setup time.                      |
| t <sub>HD; STA</sub> <sup>2</sup> | 600                                          | ns min  | Start condition hold time.                       |
| t <sub>SU; DAT</sub> <sup>3</sup> | 100                                          | ns min  | Data setup time.                                 |
| t <sub>SU; STO</sub> <sup>4</sup> | 600                                          | ns min  | Stop condition setup time.                       |
| t <sub>BUF</sub>                  | 1.3                                          | μs min  | Bus free time between stop and start conditions. |

<sup>1</sup> Guaranteed by design, but not production tested.  
<sup>2</sup> Time from 10% of SDATA to 90% of SCLK.  
<sup>3</sup> Time for 10% or 90% of SDATA to 10% of SCLK.  
<sup>4</sup> Time for 90% of SCLK to 10% of SDATA.




Figure 2. Serial Bus Timing

061150-002

## ABSOLUTE MAXIMUM RATINGS

Table 3.

| Parameter                                                          | Rating                     |
|--------------------------------------------------------------------|----------------------------|
| Positive Supply Voltage ( $V_{DD}$ ) to GND                        | –0.3 V to +3.6 V           |
| D+                                                                 | –0.3 V to $V_{DD} + 0.3$ V |
| D– to GND                                                          | –0.3 V to +0.6 V           |
| SCLK, SDATA, $\overline{\text{ALERT}}$ , $\overline{\text{THERM}}$ | –0.3 V to +3.6 V           |
| Input Current, SDATA, $\overline{\text{THERM}}$                    | –1 mA, to +50 mA           |
| Input Current, D–                                                  | ±1 mA                      |
| ESD Rating, All Pins (Human Body Model)                            | 2000 V                     |
| Maximum Junction Temperature ( $T_J$ Max)                          | 150°C                      |
| Storage Temperature Range                                          | –65°C to +150°C            |
| IR Reflow Peak Temperature                                         | 220°C                      |
| IR Reflow Peak Temperature Pb-Free                                 | 260°C                      |
| Lead Temperature (Soldering 10 sec)                                | 300°C                      |

Stresses above those listed under Absolute Maximum Ratings may cause permanent damage to the device. This is a stress rating only; functional operation of the device at these or any other conditions above those indicated in the operational section of this specification is not implied. Exposure to absolute maximum rating conditions for extended periods may affect device reliability.

### THERMAL RESISTANCE

$\theta_{JA}$  is specified for the worst-case conditions, that is, a device soldered in a circuit board for surface-mount packages.

Table 4. Thermal Resistance

| Package Type | $\theta_{JA}$ | $\theta_{JC}$ | Unit |
|--------------|---------------|---------------|------|
| 10-Lead MSOP | 142           | 43.7          | °C/W |

### ESD CAUTION

ESD (electrostatic discharge) sensitive device. Electrostatic charges as high as 4000 V readily accumulate on the human body and test equipment and can discharge without detection. Although this product features proprietary ESD protection circuitry, permanent damage may occur on devices subjected to high energy electrostatic discharges. Therefore, proper ESD precautions are recommended to avoid performance degradation or loss of functionality.



# ADT7482

## PIN CONFIGURATION AND FUNCTION DESCRIPTIONS




Figure 3. Pin Configuration

Table 5. Pin Function Descriptions

| Pin No. | Mnemonic         | Description                                                                                                                                                   |
|---------|------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1       | V <sub>DD</sub>  | Positive Supply, 3 V to 3.6 V.                                                                                                                                |
| 2       | D1+              | Positive Connection to the First Remote (Remote 1) Temperature Sensor.                                                                                        |
| 3       | D1-              | Negative Connection to the First Remote (Remote 1) Temperature Sensor.                                                                                        |
| 4       | THERM            | Open-Drain Output. This pin can be used to turn a fan on/off or throttle a CPU clock in the event of an overtemperature condition. Requires pull-up resistor. |
| 5       | GND              | Supply Ground Connection.                                                                                                                                     |
| 6       | D2-              | Negative Connection to the Second Remote (Remote 2) Temperature Sensor.                                                                                       |
| 7       | D2+              | Positive Connection to the Second Remote (Remote 2) Temperature Sensor.                                                                                       |
| 8       | ALERT<br>/THERM2 | Open-Drain Logic Output. This pin is used as interrupt or SMBus alert. May also be configured as a second THERM output. Requires pull-up resistor.            |
| 9       | SDATA            | Logic Input/Output, SMBus Serial Data. Open-drain output. Requires pull-up resistor.                                                                          |
| 10      | SCLK             | Logic Input, SMBus Serial Clock. Requires pull-up resistor.                                                                                                   |

## TYPICAL PERFORMANCE CHARACTERISTICS




Figure 4. Local Temperature Error vs. Temperature




Figure 7. Temperature Error vs. D+/D- Leakage Resistance




Figure 5. Remote 1 Temperature Error vs. Temperature




Figure 8. Temperature Error vs. D+/D- Capacitance




Figure 6. Remote 2 Temperature Error vs. Temperature




Figure 9. Operating Supply Current vs. Conversion Rate

# ADT7482




Figure 10. Operating Supply Current vs. Voltage




Figure 11. Standby Supply Current vs. Voltage




Figure 12. Standby Supply Current vs. Clock Frequency




Figure 13. Temperature Error vs. Common Mode Noise Frequency




Figure 14. Temperature Error vs. Differential Mode Noise Frequency




Figure 15. Temperature Error vs. Series Resistance

## THEORY OF OPERATION

The ADT7482 is a local and 2× remote temperature sensor and overtemperature/undertemperature alarm. When the ADT7482 is operating normally, the on-board ADC operates in a free-running mode. The analog input multiplexer alternately selects either the on-chip temperature sensor to measure its local temperature or either of the remote temperature sensors. The ADC digitizes these signals and the results are stored in the local, Remote 1, and Remote 2 temperature value registers.

The local and remote measurement results are compared with the corresponding high, low, and THERM temperature limits, stored in on-chip registers. Out-of-limit comparisons generate flags that are stored in the status register. A result that exceeds the high temperature limit, the low temperature limit, or a remote diode open circuit causes the ALERT output to assert low. Exceeding THERM temperature limits causes the THERM output to assert low. The ALERT output can be reprogrammed as a second THERM output.

The limit registers can be programmed, and the device controlled and configured, via the serial SMBus. The contents of any register can also be read back via the SMBus.

Control and configuration functions consist of switching the device between normal operation and standby mode, selecting the temperature measurement scale, masking or enabling the ALERT output, switching Pin 8 between ALERT and THERM2, and selecting the conversion rate.

### SERIES RESISTANCE CANCELLATION

Parasitic resistance to the D+ and D– inputs to the ADT7482, seen in series with the remote diode, is caused by a variety of factors, including PCB track resistance and track length. This series resistance appears as a temperature offset in the remote sensor temperature measurement. This error typically causes a 0.5°C offset per ohm of parasitic resistance in series with the remote diode.

The ADT7482 automatically cancels out the effect of this series resistance on the temperature reading, providing a more accurate result, without the need for user characterization of this resistance. The ADT7482 is designed to automatically cancel typically up to 1.5 kΩ of resistance. By using an advanced temperature measurement method, this is transparent to the user. This feature allows resistances to be added to the sensor path to produce a filter, allowing the part to be used in noisy environments. See the Noise Filtering section for more details.

### TEMPERATURE MEASUREMENT METHOD

A simple method of measuring temperature is to exploit the negative temperature coefficient of a diode, measuring the base-emitter voltage ( $V_{BE}$ ) of a transistor operated at constant current. However, this technique requires calibration to null out the effect of the absolute value of  $V_{BE}$ , which varies from device to device.

The technique used in the ADT7482 is to measure the change in  $V_{BE}$  when the device is operated at three different currents. Previous devices have used only two operating currents. The use of a third current allows automatic cancellation of resistances in series with the external temperature sensor.


Figure 16 shows the input signal conditioning used to measure the output of an external temperature sensor. This figure shows the external sensor as a substrate transistor, but it could equally be a discrete transistor. If a discrete transistor is used, the collector is not grounded and should be linked to the base. To prevent ground noise from interfering with the measurement, the more negative terminal of the sensor is not referenced to ground, but is biased above ground by an internal diode at the D– input. Capacitor C1 can be added as a noise filter (a recommended maximum value of 1000 pF). However, a better option in noisy environments is to add a filter, as described in the Noise Filtering section. See the Layout Considerations section for more information.

To measure  $\Delta V_{BE}$ , the operating current through the sensor is switched among three related currents. Shown in Figure 16,  $N1 \times I$  and  $N2 \times I$  are different multiples of the current,  $I$ . The currents through the temperature diode are switched between  $I$  and  $N1 \times I$ , giving  $\Delta V_{BE1}$ , and then between  $I$  and  $N2 \times I$ , giving  $\Delta V_{BE2}$ . The temperature can then be calculated using the two  $\Delta V_{BE}$  measurements. This method can also be shown to cancel the effect of any series resistance on the temperature measurement.

The resulting  $\Delta V_{BE}$  waveforms are passed through a 65 kHz low-pass filter to remove noise and then to a chopper-stabilized amplifier. This amplifies and rectifies the waveform to produce a dc voltage proportional to  $\Delta V_{BE}$ . The ADC digitizes this voltage and a temperature measurement is produced. To reduce the effects of noise, digital filtering is performed by averaging the results of 16 measurement cycles for low conversion rates. At rates of 16, 32, and 64 conversions/second, no digital averaging takes place.

Signal conditioning and measurement of the internal temperature sensor are performed in the same manner.

# ADT7482



<sup>1</sup> CAPACITOR C1 IS OPTIONAL. IT SHOULD ONLY BE USED IN NOISY ENVIRONMENTS.

Figure 16. Input Signal Conditioning

## TEMPERATURE MEASUREMENT RESULTS

The results of the local and remote temperature measurements are stored in the local and remote temperature value registers and are compared with limits programmed into the local and remote high and low limit registers.

The local temperature measurement is an 8-bit measurement with 1°C resolution. The remote temperature measurements are 10-bit measurements, with the 8 MSBs stored in one register and the 2 LSBs stored in another register. Table 6 is a list of the temperature measurement registers.

Table 6. Register Address for the Temperature Values

| Temperature Channel | Register Address, MSBs | Register Address, LSBs |
|---------------------|------------------------|------------------------|
| Local               | 0x00                   | N/A                    |
| Remote 1            | 0x01                   | 0x10 (2 MSBs)          |
| Remote 2            | 0x30                   | 0x33 (2 MSBs)          |

Set Bit 3 of the Configuration 1 register to 1, to read the Remote 2 temperature values from the following register addresses:

- Remote 2, MSBs = 0x01
- Remote 2, LSBs = 0x10

The above is true only when Bit 3 of the Configuration 1 register is set. To read the Remote 1 temperatures, switch this bit back to 0.

Only the two MSBs in the remote temperature low byte are used. This gives the remote temperature measurement a resolution of 0.25°C. Table 7 shows the data format for the remote temperature low byte.

Table 7. Extended Temperature Resolution (Remote Temperature Low Byte)

| Extended Resolution | Remote Temperature Low Byte |
|---------------------|-----------------------------|
| 0.00°C              | 0 000 0000                  |
| 0.25°C              | 0 100 0000                  |
| 0.50°C              | 1 000 0000                  |
| 0.75°C              | 1 100 0000                  |

When reading the full remote temperature value, both the high and low byte, the two registers should be read LSB first and then MSB. Reading the LSB causes the MSB to be locked until it is read. This guarantees that the two values are read as a result of the same temperature measurement.

## TEMPERATURE MEASUREMENT RANGE

The temperature measurement range for both local and remote measurements is, by default, 0°C to +127°C. However, the ADT7482 can be operated using an extended temperature range. It can measure the full temperature range of a remote thermal diode, from -55°C to +150°C. Switch between these two temperature ranges by setting or clearing Bit 2 in the Configuration 1 register. A valid result is available in the next measurement cycle after changing the temperature range.

In extended temperature mode, the upper and lower temperature measured by the ADT7482 is limited by the remote diode selection. The temperature registers themselves can have values from -64°C to +191°C. However, most temperature-sensing diodes have a maximum temperature range of -55°C to +150°C.

Note that while both local and remote temperature measurements can be made while the part is in extended temperature mode, the ADT7482 itself should not be exposed to temperatures greater than those specified in the Absolute Maximum Ratings section. Further, the device is only guaranteed to operate as specified at ambient temperatures from -40°C to +120°C.

## TEMPERATURE DATA FORMAT

The ADT7482 has two temperature data formats. When the temperature measurement range is from 0°C to 127°C (default), the temperature data format for both local and remote temperature results is binary.

When the measurement range is in extended mode, an offset binary data format is used for both local and remote results. Temperature values in the offset binary data format are offset by +64. Examples of temperatures in both data formats are shown in **Table 8**.

Switching between measurement ranges can be done at any time. Switching the range also switches the data format. The next temperature result following the switching is reported back to the register in the new format. However, the contents of the limit registers do not change. Ensure that when the data format changes, the limit registers are reprogrammed as necessary. For more information, refer to the Limit Registers section.

**Table 8. Temperature Data Format (Local and Remote Temperature High Byte)**

| Temperature | Binary                  | Offset Binary <sup>1</sup> |
|-------------|-------------------------|----------------------------|
| -55°C       | 0 000 0000 <sup>2</sup> | 0 000 1001                 |
| 0°C         | 0 000 0000              | 0 100 0000                 |
| +1°C        | 0 000 0001              | 0 100 0001                 |
| +10°C       | 0 000 1010              | 0 100 1010                 |
| +25°C       | 0 001 1001              | 0 101 1001                 |
| +50°C       | 0 011 0010              | 0 111 0010                 |
| +75°C       | 0 100 1011              | 1 000 1011                 |
| +100°C      | 0 110 0100              | 1 010 0100                 |
| +125°C      | 0 111 1101              | 1 011 1101                 |
| +127°C      | 0 111 1111              | 1 011 1111                 |
| +150°C      | 0 111 1111 <sup>3</sup> | 1 101 0110                 |

<sup>1</sup> Offset binary scale temperature values are offset by +64.

<sup>2</sup> Binary scale temperature measurement returns 0 for temperature < 0°C.

<sup>3</sup> Binary scale temperature measurement returns 127 for temperature > 127°C.

# ADT7482

## REGISTERS

The registers in the ADT7482 are 8-bits wide. These registers are used to store the results of remote and local temperature measurements and high and low temperature limits and to configure and control the device. A description of these registers follows.

### ADDRESS POINTER REGISTER

The address pointer register itself does not have, or require, an address, as the first byte of every write operation is automatically written to this register. The data in this first byte always contains the address of another register on the ADT7482, which is stored in the address pointer register. It is to this register address that the second byte of a write operation is written to or to which a subsequent read operation is performed.

The power-on default value of the address pointer register is 0x00. Therefore, if a read operation is performed immediately after power-on, without first writing to the address pointer, the value of the local temperature is returned, since its register address is 0x00.

### CONFIGURATION REGISTERS

There are two configuration registers used to control the operation of the ADT7482. Configuration 1 register is at Address 0x03 for reads and Address 0x09 for writes. See Table 9 for details regarding the operation of this register. Configuration 2 Register is at Address 0x24 for both reads and writes. Setting Bit

7 of this register locks all lockable registers. The affected registers can only be modified if the ADT7482 is powered down and powered up again. See Table 16 for a list of the registers affected by the lock bit.

### TEMPERATURE VALUE REGISTERS

The ADT7482 has five registers to store the results of local and remote temperature measurements. These registers can only be written to by the ADC and can be read over the SMBus.

- The local temperature value register is at Address 0x00.
- The Remote 1 temperature value high byte register is at Address 0x01; the Remote 1 low byte register is at Address 0x10.
- The Remote 2 temperature value high byte register is at Address 0x30; the Remote 2 low byte register is at Address 0x33.
- The Remote 2 temperature values can be read from Addresses 0x01 for the high byte and Address 0x10 for the low byte if Bit 3 of Configuration Register 1 is set to 1.
- To read the Remote 1 temperature values, set Bit 3 of Configuration Register 1 to 0.
- The power-on default for all five registers is 0x00.

**Table 9. Configuration 1 Register (Read Address = 0x03, Write Address = 0x09)**

| Bit | Mnemonic           | Description                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
|-----|--------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 7   | Mask               | Setting this bit to 1 masks all $\overline{\text{ALERT}}$ s on the $\overline{\text{ALERT}}$ pin. Default = 0 = $\overline{\text{ALERT}}$ enabled. This applies only if Pin 8 is configured as $\overline{\text{ALERT}}$ , otherwise it has no effect.                                                                                                                                                                                                                                                             |
| 6   | Mon/STBY           | Setting this bit to 1 places the ADT7482 in standby mode (that is, it suspends all temperature measurements (ADC). The SMBus remains active and values can be written to and read from the registers. $\overline{\text{THERM}}$ and $\overline{\text{ALERT}}$ are also active in standby mode. Changes made to the limit registers in standby mode that effect the $\overline{\text{THERM}}$ or $\overline{\text{ALERT}}$ outputs cause these signals to be updated. Default = 0 = temperature monitoring enabled. |
| 5   | AL/TH              | This bit selects the function of Pin 8. Default = 0 = $\overline{\text{ALERT}}$ . Setting this bit to 1 configures Pin 8 as $\overline{\text{THERM2}}$ pin.                                                                                                                                                                                                                                                                                                                                                        |
| 4   | Reserved           | Reserved for future use.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| 3   | Remote 1 /Remote 2 | Setting this bit to 1 enables Remote 2 values to be read from the Remote 1 registers. Default = 0 = Remote 1 temperature values and limits are read from these registers.                                                                                                                                                                                                                                                                                                                                          |
| 2   | Temp Range         | Setting this bit to 1 enables the extended temperature measurement range ( $-50^{\circ}\text{C}$ to $+150^{\circ}\text{C}$ ). Default = 0 = ( $0^{\circ}\text{C}$ to $+127^{\circ}\text{C}$ ).                                                                                                                                                                                                                                                                                                                     |
| 1   | Mask R1            | Setting this bit to 1 masks $\overline{\text{ALERT}}$ s due to the Remote 1 temperature exceeding a programmed limit. Default = 0.                                                                                                                                                                                                                                                                                                                                                                                 |
| 0   | Mask R2            | Setting this bit to 1 masks $\overline{\text{ALERT}}$ s due to the Remote 2 temperature exceeding a programmed limit. Default = 0.                                                                                                                                                                                                                                                                                                                                                                                 |

**Table 10. Configuration 2 Register (Read/Write Address = 0x24)**

| Bit   | Mnemonic | Description                                                                                                                                                                |
|-------|----------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 7     | Lock Bit | Setting this bit to 1 locks all lockable registers to their current values. This prevents settings from being tampered with until the device is powered down. Default = 0. |
| <6:0> | Res      | Reserved for future use.                                                                                                                                                   |

## CONVERSION RATE REGISTER

The conversion rate register is at Address 0x04 for reads and Address 0x0A for writes. The four LSBs of this register are used to program the conversion times from 15.5 ms (Code 0x0A) to 16 seconds (Code 0x00). To program the ADT7482 to perform continuous measurements, set the conversion rate register to 0x0B. For example, a conversion rate of 8 conversions/second means that, beginning at 125 ms intervals, the device performs a conversion on the local and the remote temperature channels. The four MSBs of this register are reserved and should not be written to.

This register can be written to and read back over the SMBus. The default value of this register is 0x07, giving a rate of 8 conversions per second. Use of slower conversion times greatly reduces the device power consumption.

## LIMIT REGISTERS

The ADT7482 has three limits for each temperature channel: high, low, and  $\overline{\text{THERM}}$  temperature limits for local, Remote 1, and Remote 2 temperature measurements. The remote temperature high and low limits span two registers each, to contain an upper and lower byte for each limit. There is also a  $\overline{\text{THERM}}$  hysteresis register. All limit registers can be written to and read back over the SMBus. See Table 16 for limit register addresses and power-on default values.

When Pin 8 is configured as an  $\overline{\text{ALERT}}$  output, the high limit registers perform a  $>$  comparison while the low limit registers perform a  $\leq$  comparison. For example, if the high limit register is programmed with 80°C, then measuring 81°C results in an out-of-limit condition, setting a flag in the status register. If the low limit register is programmed with 0°C, measuring 0°C or lower results in an out-of-limit condition.

Exceeding either the local or remote  $\overline{\text{THERM}}$  limit asserts  $\overline{\text{THERM}}$  low. When Pin 8 is configured as  $\overline{\text{THERM2}}$ , exceeding either the local or remote high limit asserts  $\overline{\text{THERM2}}$  low. A default hysteresis value of 10°C is provided that applies to both  $\overline{\text{THERM}}$  channels. This hysteresis value can be reprogrammed.

It is important to remember that the temperature limits data format is the same as the temperature measurement data format. If the temperature measurement uses the default binary scale, then the temperature limits also use the binary scale. If the temperature measurement scale is switched, however, the temperature limits do not switch automatically.

The limit registers must be reprogrammed to the desired value in the correct data format. For example, if the remote low limit is set at 10°C and the default binary scale is used, the limit register value should be 0000 1010b. If the scale is switched to offset binary, the value in the low temperature limit register should be reprogrammed to be 0100 1010b.

**Table 11. Conversion Rate Register (Read Address = 0x04, Write Address = 0x0A)**

| Bit                | Mnemonic         | Function                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
|--------------------|------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------|----------------|---------------|----|--------------|---|-------------|---|------------|---|----------|---|----------|-------|----------|-------|--------------------|-------|-----------|--------|-----------|---------|-----------|--------|
| 7                  | Reserved         | Reserved for future use. Do not write to this bit.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 6                  | Reserved         | Reserved for future use . Do not write to this bit.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 5                  | Reserved         | Reserved for future use . Do not write to this bit.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 4                  | Reserved         | Reserved for future use. Do not write to this bit.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| <3:0>              | Conversion rates | These bits set how often the ADT7482 measures each temperature channel. <table><tr><th>Conversions/sec</th><th>Time (seconds)</th></tr><tr><td>0000 = 0.0625</td><td>16</td></tr><tr><td>0001 = 0.125</td><td>8</td></tr><tr><td>0010 = 0.25</td><td>4</td></tr><tr><td>0011 = 0.5</td><td>2</td></tr><tr><td>0100 = 1</td><td>1</td></tr><tr><td>0101 = 2</td><td>500 m</td></tr><tr><td>0110 = 4</td><td>250 m</td></tr><tr><td>0111 = 8 = default</td><td>125 m</td></tr><tr><td>1000 = 16</td><td>62.5 m</td></tr><tr><td>1001 = 32</td><td>31.25 m</td></tr><tr><td>1010 = 64</td><td>15.5 m</td></tr></table> | Conversions/sec | Time (seconds) | 0000 = 0.0625 | 16 | 0001 = 0.125 | 8 | 0010 = 0.25 | 4 | 0011 = 0.5 | 2 | 0100 = 1 | 1 | 0101 = 2 | 500 m | 0110 = 4 | 250 m | 0111 = 8 = default | 125 m | 1000 = 16 | 62.5 m | 1001 = 32 | 31.25 m | 1010 = 64 | 15.5 m |
| Conversions/sec    | Time (seconds)   |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 0000 = 0.0625      | 16               |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 0001 = 0.125       | 8                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 0010 = 0.25        | 4                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 0011 = 0.5         | 2                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 0100 = 1           | 1                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 0101 = 2           | 500 m            |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 0110 = 4           | 250 m            |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 0111 = 8 = default | 125 m            |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 1000 = 16          | 62.5 m           |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 1001 = 32          | 31.25 m          |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |
| 1010 = 64          | 15.5 m           |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                 |                |               |    |              |   |             |   |            |   |          |   |          |       |          |       |                    |       |           |        |           |         |           |        |

# ADT7482

## STATUS REGISTERS

The status registers are read-only registers at Addresses 0x02 (Status Register 1) and Address 0x23 (Status Register 2). They contain status information for the ADT7482.

**Table 12. Status Register 1 Bit Assignments**

| Bit | Name                 | Function                                               | ALERT |
|-----|----------------------|--------------------------------------------------------|-------|
| 7   | BUSY                 | 1 when ADC converting                                  | No    |
| 6   | LHIGH <sup>1</sup>   | 1 when local high temperature limit tripped            | Yes   |
| 5   | LLOW <sup>1</sup>    | 1 when local low temperature limit tripped             | Yes   |
| 4   | R1HIGH <sup>1</sup>  | 1 when Remote 1 high temperature limit tripped         | Yes   |
| 3   | R1LOW <sup>1</sup>   | 1 when Remote 1 low temperature limit tripped          | Yes   |
| 2   | D1 OPEN <sup>1</sup> | 1 when Remote 1 sensor open circuit                    | Yes   |
| 1   | R1THRM1              | 1 when Remote1 $\overline{\text{THERM}}$ limit tripped | No    |
| 0   | LTHRM1               | 1 when local $\overline{\text{THERM}}$ limit tripped   | No    |

<sup>1</sup>These flags stay high until the status register is read, or they are reset by POR.

**Table 13. Status Register 2 Bit Assignments**

| Bit | Name                      | Function                                               | ALERT |
|-----|---------------------------|--------------------------------------------------------|-------|
| 7   | Res                       | Reserved for future use                                | No    |
| 6   | Res                       | Reserved for future use                                | No    |
| 5   | Res                       | Reserved for future use                                | No    |
| 4   | R2HIGH <sup>1</sup>       | 1 when Remote 2 high temperature limit tripped         | Yes   |
| 3   | R2LOW <sup>1</sup>        | 1 when Remote 2 low temperature limit tripped          | Yes   |
| 2   | D2 OPEN <sup>1</sup>      | 1 when Remote 2 sensor open circuit                    | Yes   |
| 1   | R2THRM1                   | 1 when Remote2 $\overline{\text{THERM}}$ limit tripped | No    |
| 0   | $\overline{\text{ALERT}}$ | 1 when $\overline{\text{ALERT}}$ condition exists.     | No    |

<sup>1</sup>These flags stay high until the status register is read, or they are reset by POR.

The eight flags that can generate an  $\overline{\text{ALERT}}$  are NOR'd together. When any flags are high, the  $\overline{\text{ALERT}}$  interrupt latch is set and the  $\overline{\text{ALERT}}$  output goes low (provided they are not masked out).

Reading the Status 1 register clears the 5 flags, (Bit 6 through Bit 2) in Status Register 1, provided the error conditions that caused the flags to be set have gone away. Reading the Status 2 Register clears the three flags, (Bit 4 through Bit 2) in Status Register 2, provided the error conditions that caused the flags to be set have gone away. A flag bit can only be reset if the corresponding value register contains an in-limit measurement or if the sensor is good.

The  $\overline{\text{ALERT}}$  interrupt latch is not reset by reading the status register. It is reset when the  $\overline{\text{ALERT}}$  output has been serviced by the master reading the device address, provided the error

condition has gone away and the status register flag bits have been reset.

When Flag 1 and/or Flag 0 of Status Register 1 or Flag 1 of Status Register 2 are set, the  $\overline{\text{THERM}}$  output goes low to indicate that the temperature measurements are outside the programmed limits. The  $\overline{\text{THERM}}$  output does not need to be reset, unlike the  $\overline{\text{ALERT}}$  output. Once the measurements are within the limits, the corresponding status register bits are reset automatically, and the  $\overline{\text{THERM}}$  output goes high. To add hysteresis, program Register 0x21. The  $\overline{\text{THERM}}$  output is reset only when the temperature falls below the  $\overline{\text{THERM}}$  limit minus hysteresis.

When Pin 8 is configured as  $\overline{\text{THERM2}}$ , only the high temperature limits are relevant. If Flag 6 or Flag 4 of Status Register 1 or Flag 4 of Status Register 2 are set, the  $\overline{\text{THERM2}}$  output goes low to indicate that the temperature measurements are outside the programmed limits. Flag 5 and Flag 3 of Status Register 1 and Flag 3 of Status Register 2 have no effect on  $\overline{\text{THERM2}}$ . The behavior of  $\overline{\text{THERM2}}$  is otherwise the same as  $\overline{\text{THERM}}$ .

Bit 0 of the Status Register 2 is set whenever the ADT7482  $\overline{\text{ALERT}}$  output is asserted low. Read Status Register 2 to determine if the ADT7482 is responsible for the  $\overline{\text{ALERT}}$ . This bit is reset when the  $\overline{\text{ALERT}}$  output is reset. If the  $\overline{\text{ALERT}}$  output is masked, then this bit is not set.

## OFFSET REGISTER

Offset errors can be introduced into the remote temperature measurement by clock noise or by the thermal diode being located away from the hot spot. To achieve the specified accuracy on this channel, these offsets must be removed.

The offset values are stored as 10-bit, twos complement values.

- The Remote 1 Offset MSBs are stored in Register 0x11 and the LSBs are stored in Register 0x12 (low byte, left justified). The Remote 2 Offset MSBs are stored in Register 0x34 and the LSBs are stored in Register 0x35 (low byte, left justified).
- The Remote 2 Offset can be written to or read from the Remote 1 Offset Registers if Bit 3 of the Configuration 1 register is set to 1. This bit should be set to 0 (default) to read the Remote 1 offset values.

Only the upper 2 bits of the LSB registers are used. The MSB of MSB offset registers is the sign bit. The minimum offset that can be programmed is  $-128^{\circ}\text{C}$ , and the maximum is  $+127.75^{\circ}\text{C}$ . The value in the offset register is added or subtracted to the measured value of the remote temperature.

The offset register powers up with a default value of  $0^{\circ}\text{C}$  and has no effect unless a different value is written to it.

Table 14. Sample Offset Register Codes

| Offset Value | 0x11/0x34 | 0x12/0x35  |
|--------------|-----------|------------|
| –128°C       | 1000 0000 | 00 00 0000 |
| –4°C         | 1111 1100 | 00 00 0000 |
| –1°C         | 1111 1111 | 00 000000  |
| –0.25°C      | 1111 1111 | 11 00 0000 |
| 0°C          | 0000 0000 | 00 00 0000 |
| +0.25°C      | 0000 0000 | 01 00 0000 |
| +1°C         | 0000 0001 | 00 00 0000 |
| +4°C         | 0000 0100 | 00 00 0000 |
| +127.75°C    | 0111 1111 | 11 00 0000 |

### ONE-SHOT REGISTER

The one-shot register initiates a conversion and comparison cycle when the ADT7482 is in standby mode, after which the device returns to standby. Writing to the one-shot register address (0x0F) causes the ADT7482 to perform a conversion and comparison on both the local and the remote temperature channels. This is not a data register as such, and it is the write operation to Address 0x0F that causes the one-shot conversion. The data written to this address is irrelevant and is not stored.

### CONSECUTIVE ALERT REGISTER

The value written to this register determines how many out-of-limit measurements must occur before an ALERT is generated. The default value is that one out-of-limit measurement generates an ALERT. The maximum value that can be chosen is 4. This register allows some filtering of the output. This is particularly useful at the fastest three conversion rates, where no averaging takes place. This register address is 0x22. For more information, refer to Table 15.

Table 15. Consecutive ALERT Register Bit

| Register Value <sup>1</sup> | Amount of Out-of-Limit Measurements Required |
|-----------------------------|----------------------------------------------|
| yzax 000x                   | 1                                            |
| yzax 001x                   | 2                                            |
| yzax 011x                   | 3                                            |
| yzax 111x                   | 4                                            |

<sup>1</sup> Notes:

y = SMBus SCL timeout bit. Default = 0. See the Serial Bus Interface section for more information.

z = SMBus SDA timeout bit. Default = 0. See the Serial Bus Interface section for more information.

a = Mask Internal ALERTs.

x = Don't care bit.

# ADT7482

Table 16. List of Registers

| Read Address (Hex) | Write Address (Hex) | Name                                      | Power-On Default        | Comment              | Lock |
|--------------------|---------------------|-------------------------------------------|-------------------------|----------------------|------|
| N/A                | N/A                 | Address Pointer                           | Undefined               |                      | No   |
| 00                 | N/A                 | Local Temperature Value                   | 0000 0000 (0x00)        |                      | No   |
| 01                 | N/A                 | Remote 1 Temperature Value High Byte      | 0000 0000 (0x00)        | Bit 3 Conf. Reg. = 0 | No   |
| 01                 | N/A                 | Remote 2 Temperature Value High Byte      | 0000 0000 (0x00)        | Bit 3 Conf. Reg. = 1 | No   |
| 02                 | N/A                 | Status Register 1                         | Undefined               |                      | No   |
| 03                 | 09                  | Configuration Register 1                  | 0000 0000 (0x00)        |                      | Yes  |
| 04                 | 0A                  | Conversion Rate                           | 0000 0111 (0x07)        |                      | Yes  |
| 05                 | 0B                  | Local Temperature High Limit              | 0101 0101 (0x55) (85°C) |                      | Yes  |
| 06                 | 0C                  | Local Temperature Low Limit               | 0000 0000 (0x00) (0°C)  |                      | Yes  |
| 07                 | 0D                  | Remote 1 Temperature High Limit High Byte | 0101 0101 (0x55) (85°C) | Bit 3 Conf. Reg. = 0 | Yes  |
| 07                 | 0D                  | Remote 2 Temperature High Limit High Byte | 0101 0101 (0x55) (85°C) | Bit 3 Conf. Reg. = 1 | Yes  |
| 08                 | 0E                  | Remote 1 Temperature Low Limit High Byte  | 0000 0000 (0x00) (0°C)  | Bit 3 Conf. Reg. = 0 | Yes  |
| 08                 | 0E                  | Remote 2 Temperature Low Limit High Byte  | 0000 0000 (0x00) (0°C)  | Bit 3 Conf. Reg. = 1 | Yes  |
| N/A                | 0F <sup>1</sup>     | One Shot                                  |                         |                      | N/A  |
| 10                 | N/A                 | Remote 1 Temperature Value Low Byte       | 0000 0000               | Bit 3 Conf. Reg. = 0 | No   |
| 10                 | N/A                 | Remote 2 Temperature Value Low Byte       | 0000 0000               | Bit 3 Conf. Reg. = 1 | No   |
| 11                 | 11                  | Remote 1 Temperature Offset High Byte     | 0000 0000               | Bit 3 Conf. Reg. = 0 | Yes  |
| 11                 | 11                  | Remote 2 Temperature Offset High Byte     | 0000 0000               | Bit 3 Conf. Reg. = 1 | Yes  |
| 12                 | 12                  | Remote 1 Temperature Offset Low Byte      | 0000 0000               | Bit 3 Conf. Reg. = 0 | Yes  |
| 12                 | 12                  | Remote 2 Temperature Offset Low Byte      | 0000 0000               | Bit 3 Conf. Reg. = 1 | Yes  |
| 13                 | 13                  | Remote 1 Temperature High Limit Low Byte  | 0000 0000               | Bit 3 Conf. Reg. = 0 | Yes  |
| 13                 | 13                  | Remote 2 Temperature High Limit Low Byte  | 0000 0000               | Bit 3 Conf. Reg. = 1 | Yes  |
| 14                 | 14                  | Remote 1 Temperature Low Limit Low Byte   | 0000 0000               | Bit 3 Conf. Reg. = 0 | Yes  |
| 14                 | 14                  | Remote 2 Temperature Low Limit Low Byte   | 0000 0000               | Bit 3 Conf. Reg. = 1 | Yes  |
| 19                 | 19                  | Remote 1 $\overline{\text{THERM}}$ Limit  | 0101 0101 (0x55) (85°C) | Bit 3 Conf. Reg. = 0 | Yes  |
| 19                 | 19                  | Remote 2 $\overline{\text{THERM}}$ Limit  | 0101 0101 (0x55) (85°C) | Bit 3 Conf. Reg. = 1 | Yes  |
| 20                 | 20                  | Local $\overline{\text{THERM}}$ Limit     | 0101 0101 (0x55) (85°C) |                      | Yes  |
| 21                 | 21                  | $\overline{\text{THERM}}$ Hysteresis      | 0000 1010 (0x0A) (10°C) |                      | Yes  |
| 22                 | 22                  | Consecutive $\overline{\text{ALERT}}$     | 0000 0001 (0x01)        |                      | Yes  |
| 23                 | N/A                 | Status Register 2                         | 0000 0000 (0x00)        |                      | No   |
| 24                 | 24                  | Configuration 2 Register                  | 0000 0000 (0x00)        |                      | Yes  |
| 30                 | N/A                 | Remote 2 Temperature Value High Byte      | 0000 0000 (0x00)        |                      | No   |
| 31                 | 31                  | Remote 2 Temperature High Limit High Byte | 0101 0101 (0x55) (85°C) |                      | Yes  |
| 32                 | 32                  | Remote 2 Temperature Low Limit High Byte  | 0000 0000 (0x00) (0°C)  |                      | Yes  |
| 33                 | N/A                 | Remote 2 Temperature Value Low Byte       | 0000 0000 (0x00)        |                      | No   |
| 34                 | 34                  | Remote 2 Temperature Offset High Byte     | 0000 0000 (0x00)        |                      | Yes  |
| 35                 | 35                  | Remote 2 Temperature Offset Low Byte      | 0000 0000 (0x00)        |                      | Yes  |
| 36                 | 36                  | Remote 2 Temperature High Limit Low Byte  | 0000 0000 (0x00) (0°C)  |                      | Yes  |
| 37                 | 37                  | Remote 2 Temperature Low Limit Low Byte   | 0000 0000 (0x00) (0°C)  |                      | Yes  |
| 39                 | 39                  | Remote 2 $\overline{\text{THERM}}$ Limit  | 0101 0101 (0x55) (85°C) |                      | Yes  |
| FE                 | N/A                 | Manufacturer ID                           | 0100 0001 (0x41)        |                      | N/A  |
| FF                 | N/A                 | Die Revision Code                         | 0110 0101 (0x65)        |                      | N/A  |

<sup>1</sup> Writing to address 0F causes the ADT7482 to perform a single measurement. It is not a data register as such and it does not matter what data is written to it.

## SERIAL BUS INTERFACE

Control of the ADT7482 is achieved via the serial bus. The ADT7482 is connected to this bus as a slave device, under the control of a master device.

The ADT7482 has an SMBus timeout feature. When this is enabled, the SMBus times out after typically 25 ms of no activity. However, this feature is not enabled by default. Set Bit 7 (SCL Timeout Bit) of the consecutive alert register (Address = 0x22) to enable the SCL Timeout. Set Bit 6 (SDA Timeout Bit) of the consecutive alert register (Address = 0x22) to enable the SDA Timeout.

Consult the SMBus 1.1 specification for more information.

### ADDRESSING THE DEVICE

In general, every SMBus device has a 7-bit device address, except for some devices that have extended, 10-bit addresses. When the master device sends a device address over the bus, the slave device with that address responds. The ADT7482 is available with one device address, 0x4C (1001 100b). The address mentioned in this data sheet is a 7-bit address. The  $\overline{R/\overline{W}}$  bit needs to be added to arrive at an 8-bit address.

### Serial Bus Protocol Operation

The master initiates data transfer by establishing a start condition, defined as a high-to-low transition on the serial data line SDATA while the serial clock line SCLK remains high. This indicates that an address/data stream follows.

All slave peripherals connected to the serial bus respond to the start condition and shift in the next eight bits, consisting of a 7-bit address (MSB first) plus an  $\overline{R/\overline{W}}$  bit, which determines the direction of the data transfer, that is, whether data is to be written to or read from the slave device. The peripheral whose address corresponds to the transmitted address responds by pulling the data line low during the low period before the ninth clock pulse, known as the acknowledge bit. All other devices on the bus now remain idle while the selected device waits for data to be read from or written to it. If the  $\overline{R/\overline{W}}$  bit is a 0, the master writes to the slave device. If the  $\overline{R/\overline{W}}$  bit is a 1, the master reads from the slave device.

Data is sent over the serial bus in a sequence of nine clock pulses, eight bits of data followed by an acknowledge bit from the slave device. Transitions on the data line must occur during the low period of the clock signal and remain stable during the high period, since a low-to-high transition when the clock is high can be interpreted as a stop signal. The number of data bytes that can be transmitted over the serial bus in a single read or write operation is limited only by what the master and slave devices can handle.

When all data bytes have been read or written, stop conditions are established. In write mode, the master pulls the data line high during the tenth clock pulse to assert a stop condition. In read mode, the master device overrides the acknowledge bit by pulling the data line high during the low period before the ninth clock pulse. This is known as no acknowledge. The master then takes the data line low during the low period before the tenth clock pulse, then high during the tenth clock pulse to assert a stop condition.

Any number of bytes of data can be transferred over the serial bus in one operation, but it is not possible to mix read and write in one operation because the type of operation is determined at the beginning and cannot subsequently be changed without starting a new operation. In the case of the ADT7482, write operations contain either one or two bytes, while read operations contain one byte.

To write data to one of the device data registers or to read data from it, the address pointer register must be set so that the correct data register is addressed. The first byte of a write operation always contains a valid address that is stored in the address pointer register. If data is to be written to the device, the write operation contains a second data byte that is written to the register selected by the address pointer register.

The device address is sent over the bus followed by  $\overline{R/\overline{W}}$  set to 0. This is followed by two data bytes. The first data byte is the address of the internal data register to be written to, which is stored in the address pointer register. The second data byte is the data to be written to the internal data register.

# ADT7482




Figure 17. Writing a Register Address to the Address Pointer Register, then Writing Data to the Selected Register




Figure 18. Writing to the Address Pointer Register Only




Figure 19. Reading from a Previously Selected Register

## Reading Data from a Register

When reading data from a register there are two possibilities:

- If the ADT7482 address pointer register value is unknown or not the desired value, it is first necessary to set it to the correct value before data can be read from the desired data register. This is done by performing a write to the ADT7482 as before, but only the data byte containing the register read address is sent, as data is not to be written to the register. This is shown in Figure 18.

A read operation is then performed consisting of the serial bus address,  $R/\overline{W}$  bit set to 1, followed by the data byte read from the data register. This is shown in Figure 19.

- If the address pointer register is known to be already at the desired address, data can be read from the corresponding data register without first writing to the address pointer register and the bus transaction shown in Figure 18 can be omitted.

When reading data from a register, it is important to note the following points:

1. It is possible to read a data byte from a data register without first writing to the address pointer register. However, if the address pointer register is already at the correct value, it is not possible to write data to a register without writing to the address pointer register. This is because the first data byte of a write is always written to the address pointer register.
2. Remember that some of the ADT7482 registers have different addresses for read and write operations. The write address of a register must be written to the address pointer if data is to be written to that register, but it may not be possible to read data from that address. The read address of a register must be written to the address pointer before data can be read from that register.

## ALERT OUTPUT

Pin 8 can be configured as an  $\overline{\text{ALERT}}$  output. The  $\overline{\text{ALERT}}$  output goes low whenever an out-of-limit measurement is detected, or if the remote temperature sensor is an open circuit. It is an open-drain output and requires a pull-up to  $V_{DD}$ . Several  $\overline{\text{ALERT}}$  outputs can be wire-ORed together, so that the common line goes low if one or more of the  $\overline{\text{ALERT}}$  outputs goes low.

The  $\overline{\text{ALERT}}$  output can be used as an interrupt signal to a processor, or it can be used as an  $\overline{\text{SMBALERT}}$ . Slave devices on the SMBus cannot normally signal to the bus master that they want to talk, but the  $\overline{\text{SMBALERT}}$  function allows them to do so.

One or more  $\overline{\text{ALERT}}$  outputs can be connected to a common  $\overline{\text{SMBALERT}}$  line connected to the master. When the  $\overline{\text{SMBALERT}}$  line is pulled low by one of the devices, the following procedure occurs as illustrated in Figure 20.




Figure 20. Use of  $\overline{\text{SMBALERT}}$

1.  $\overline{\text{SMBALERT}}$  is pulled low.
2. Master initiates a read operation and sends the alert response address (ARA = 0001 100). This is a general call address that should not be used as a specific device address.
3. The device whose  $\overline{\text{ALERT}}$  output is low responds to the alert response address and the master reads its device address. As the device address is seven bits, an LSB of 1 is added. The address of the device is now known and it can be interrogated in the usual way.
4. If more than one device has a low  $\overline{\text{ALERT}}$ , the one with the lowest device address has priority, in accordance with normal SMBus arbitration.
5. Once the ADT7482 has responded to the alert response address, it resets its  $\overline{\text{ALERT}}$  output, provided that the error condition that caused the  $\overline{\text{ALERT}}$  no longer exists. If the  $\overline{\text{SMBALERT}}$  line remains low, the master sends the ARA again, and so on until all devices with low  $\overline{\text{ALERT}}$  outputs respond.

## LOW POWER STANDBY MODE

The ADT7482 can be put into low power standby mode by setting Bit 6 (Mon/STBY bit) of the Configuration 1 register (Read Address = 0x03, Write Address = 0x09) to 1. When Bit 6 is 0, the ADT7482 operates normally. When Bit 6 is 1, the ADC

is inhibited, and any conversion in progress is terminated without writing the result to the corresponding value register.

The SMBus is still enabled in low power standby mode. Power consumption in this standby mode is reduced to a typical of 5  $\mu\text{A}$  if there is no SMBus activity or up to 30  $\mu\text{A}$  if there are clock and data signals on the bus.

When the device is in standby mode, it is still possible to initiate a one-shot conversion of all channels by writing to the one-shot register (Address 0x0F), after which the device returns to standby. It does not matter what is written to the one-shot register as all data written to it is ignored. It is also possible to write new values to the limit register while in standby mode. If the values stored in the temperature value registers are now outside the new limits, an  $\overline{\text{ALERT}}$  is generated, even though the ADT7482 is still in standby mode.

## SENSOR FAULT DETECTION

The ADT7482 has sensor fault detection circuitry internally at its D+ inputs. This circuit can detect situations where a remote diode is not connected, or is incorrectly connected, to the ADT7482. A simple voltage comparator trips if the voltage at D+ exceeds  $V_{DD} - 1\text{ V}$  (typical), signifying an open circuit between D+ and D-. The output of this comparator is checked when a conversion is initiated. Bit 2 (D1 OPEN flag) of the StatusRegister 1 (Address 0x02) is set if a fault is detected on the Remote 1 channel. Bit 2 (D2 OPEN flag) of the Status Register 2 (Address 0x23) is set if a fault is detected on the Remote 2 channel. If the  $\overline{\text{ALERT}}$  pin is enabled, setting this flag causes  $\overline{\text{ALERT}}$  to assert low.

If a remote sensor is not used with the ADT7482, then the D+ and D- inputs of the ADT7482 need to be tied together to prevent the OPEN flag from being set continuously.

Most temperature sensing diodes have an operating temperature range of  $-55^{\circ}\text{C}$  to  $+150^{\circ}\text{C}$ . Above  $150^{\circ}\text{C}$ , they lose their semiconductor characteristics and approximate conductors instead. This results in a diode short, setting the open flag. The remote diode in this case no longer gives an accurate temperature measurement. A read of the temperature result register gives the last good temperature measurement. Be aware that while the diode fault is triggered, the temperature measurement on the remote channels may not be accurate.

## INTERRUPT SYSTEM

The ADT7482 has two interrupt outputs,  $\overline{\text{ALERT}}$  and  $\overline{\text{THERM}}$ . Both have different functions and behavior.  $\overline{\text{ALERT}}$  is maskable and responds to violations of software-programmed temperature limits or an open-circuit fault on the remote diode.  $\overline{\text{THERM}}$  is intended as a fail-safe interrupt output that cannot be masked.

If the Remote 1, Remote 2, or local temperature exceeds the programmed high temperature limits, or equals or exceeds the

# ADT7482

low temperature limits, the  $\overline{\text{ALERT}}$  output is asserted low. An open-circuit fault on the remote diode also causes  $\overline{\text{ALERT}}$  to assert.  $\overline{\text{ALERT}}$  is reset when serviced by a master reading its device address, provided the error condition has gone away, and the status register has been reset.

The  $\overline{\text{THERM}}$  output asserts low if the Remote 1, Remote 2, or local temperature exceeds the programmed  $\overline{\text{THERM}}$  limits. The  $\overline{\text{THERM}}$  temperature limits should normally be equal to or greater than the high temperature limits.  $\overline{\text{THERM}}$  is reset automatically when the temperature falls back within the ( $\overline{\text{THERM}}$  – hysteresis) limit. The local and remote  $\overline{\text{THERM}}$  limits are set by default to 85°C. A hysteresis value can be programmed, in which case,  $\overline{\text{THERM}}$  resets when the temperature falls to the limit value minus the hysteresis value. This applies to both local and remote measurement channels. The power-on hysteresis default value is 10°C, but this can be reprogrammed to any value after power-up.

The hysteresis loop on the  $\overline{\text{THERM}}$  outputs is useful when  $\overline{\text{THERM}}$  is used for on/off control of a fan. The system can be set up so that when  $\overline{\text{THERM}}$  asserts, a fan can be switched on to cool the system. When  $\overline{\text{THERM}}$  goes high again, the fan can be switched off. Programming a hysteresis value protects from fan jitter, where the temperature hovers around the  $\overline{\text{THERM}}$  limit, and the fan is constantly being switched on and off.

**Table 17.  $\overline{\text{THERM}}$  Hysteresis**

| $\overline{\text{THERM}}$ Hysteresis | Binary Representation |
|--------------------------------------|-----------------------|
| 0°C                                  | 0 000 0000            |
| 1°C                                  | 0 000 0001            |
| 10°C                                 | 0 000 1010            |

If the ADT7482 is in the default temperature range (0°C to 127°C), then  $\overline{\text{THERM}}$  hysteresis must be less than the  $\overline{\text{THERM}}$  limit.

Figure 21 shows how the  $\overline{\text{THERM}}$  and  $\overline{\text{ALERT}}$  outputs operate. If desired, use the  $\overline{\text{ALERT}}$  output as a  $\overline{\text{SMBALERT}}$  to signal to the host via the SMBus that the temperature has risen. Use the  $\overline{\text{THERM}}$  output to turn on a fan to cool the system, if the temperature continues to increase. This method ensures that there is a fail-safe mechanism to cool the system, without the need for host intervention.




Figure 21. Operation of the  $\overline{\text{ALERT}}$  and  $\overline{\text{THERM}}$  Interrupts

1. If the measured temperature exceeds the high temperature limit, the  $\overline{\text{ALERT}}$  output asserts low.
2. If the temperature continues to increase and exceeds the  $\overline{\text{THERM}}$  limit, the  $\overline{\text{THERM}}$  output asserts low. This can be used to throttle the CPU clock or switch on a fan.
3. The  $\overline{\text{THERM}}$  output de-asserts (goes high) when the temperature falls to  $\overline{\text{THERM}}$  limit minus hysteresis. In Figure 21, the default hysteresis value of 10°C is shown.
4. The  $\overline{\text{ALERT}}$  output de-asserts only when the temperature has fallen below the high temperature limit, and the master has read the device address and cleared the status register.

Pin 8 on the ADT7482 can be configured as either an  $\overline{\text{ALERT}}$  output or as an additional  $\overline{\text{THERM}}$  output.  $\overline{\text{THERM2}}$  asserts low when the temperature exceeds the programmed local and/or remote high temperature limits. It is reset in the same manner as  $\overline{\text{THERM}}$ , and it is not maskable. The programmed hysteresis value applies to  $\overline{\text{THERM2}}$  also.

Figure 22 shows how  $\overline{\text{THERM}}$  and  $\overline{\text{THERM2}}$  might operate together to implement two methods of cooling the system. In this example, the  $\overline{\text{THERM2}}$  limits are set lower than the  $\overline{\text{THERM}}$  limits. The  $\overline{\text{THERM2}}$  output could be used to turn on a fan. If the temperature continues to rise and exceeds the  $\overline{\text{THERM}}$  limits, the  $\overline{\text{THERM}}$  output could provide additional cooling by throttling the CPU.




Figure 22. Operation of the  $\overline{\text{THERM}}$  and  $\overline{\text{THERM2}}$  Interrupts

06150-022

1. When the  $\overline{\text{THERM2}}$  limit is exceeded, the  $\overline{\text{THERM2}}$  signal asserts low.
2. If the temperature continues to increase and exceeds the  $\overline{\text{THERM}}$  limit, the  $\overline{\text{THERM}}$  output asserts low.
3. The  $\overline{\text{THERM}}$  output de-asserts (goes high) when the temperature falls to  $\overline{\text{THERM}}$  limit minus hysteresis. In Figure 22, there is no hysteresis value shown.
4. As the system cools further, and the temperature falls below the  $\overline{\text{THERM2}}$  limit, the  $\overline{\text{THERM2}}$  signal resets. Again, no hysteresis value is shown for  $\overline{\text{THERM2}}$ .

The temperature measurement could be either the local or the remote temperature measurement.

# ADT7482

## APPLICATIONS INFORMATION

### NOISE FILTERING

For temperature sensors operating in noisy environments, the previous practice was to place a capacitor across the D+ pin and the D– pins to help combat the effects of noise. However, large capacitances affect the accuracy of the temperature measurement, leading to a recommended maximum capacitor value of 1000 pF. While this capacitor reduces the noise, it does not eliminate it, making it difficult to use the sensor in a very noisy environment.

The ADT7482 has a major advantage over other devices for eliminating the effects of noise on the external sensor. The series resistance cancellation feature allows a filter to be constructed between the external temperature sensor and the part. The effect of any filter resistance seen in series with the remote sensor is automatically cancelled from the temperature result.

The construction of a filter allows the ADT7482 and the remote temperature sensor to operate in noisy environments. Figure 23 shows a low-pass R-C-R filter, with the following values:

$$R = 100\ \Omega \text{ and } C = 1\ \text{nF}$$

This filtering reduces both common-mode noise and differential noise.




Figure 23. Filter Between Remote Sensor and ADT7482

### FACTORS AFFECTING DIODE ACCURACY

#### Remote Sensing Diode

The ADT7482 is designed to work with substrate transistors built into processors or with discrete transistors. Substrate transistors are generally PNP types with the collector connected to the substrate. Discrete types can be either PNP or NPN transistors connected as a diode (base shorted to collector). If an NPN transistor is used, the collector and base are connected to D+ and the emitter to D–. If a PNP transistor is used, the collector and base are connected to D– and the emitter to D+.

To reduce the error due to variations in both substrate and discrete transistors, a number of factors should be taken into consideration:

- The ideality factor,  $n_f$ , of the transistor is a measure of the deviation of the thermal diode from ideal behavior. The ADT7482 is trimmed for an  $n_f$  value of 1.008. The following equation can be used to calculate the error introduced at a temperature  $T$  (°C), when using a transistor whose  $n_f$  does not equal 1.008. Consult the processor data sheet for the  $n_f$  values.

$$\Delta T = (n_f - 1.008) / 1.008 \times (273.15\ \text{Kelvin} + T)$$

To factor this in, write the  $\Delta T$  value to the offset register. It is then automatically added to or subtracted from the temperature measurement by the ADT7482.

- Some CPU manufacturers specify the high and low current levels of the substrate transistors. The high current level of the ADT7482,  $I_{\text{HIGH}}$ , is 220  $\mu\text{A}$  and the low level current,  $I_{\text{LOW}}$ , is 13.5  $\mu\text{A}$ . If the ADT7482 current levels do not match the current levels specified by the CPU manufacturer, it may be necessary to remove an offset. The CPU data sheet advises whether this offset needs to be removed and how to calculate it. This offset can be programmed to the offset register. It is important to note that if more than one offset must be considered, the algebraic sum of these offsets must be programmed to the offset register.

If a discrete transistor is being used with the ADT7482, the best accuracy is obtained by choosing devices according to the following criteria:

- Base-emitter voltage greater than 0.25 V at 6  $\mu\text{A}$ , at the highest operating temperature.
- Base-emitter voltage less than 0.95 V at 100  $\mu\text{A}$ , at the lowest operating temperature.
- Base resistance less than 100  $\Omega$ .
- Small variation in  $h_{\text{FE}}$  (such as 50 to 150) that indicates tight control of  $V_{\text{BE}}$  characteristics.

Transistors, such as 2N3904, 2N3906, or equivalents in SOT-23 packages, are suitable devices to use.

### THERMAL INERTIA AND SELF-HEATING

Accuracy depends on the temperature of the remote sensing diode and/or the local temperature sensor being at the same temperature as that being measured. A number of factors can affect this. Ideally, the sensor should be in good thermal contact with the part of the system being measured. If it is not, the thermal inertia caused by the sensor's mass causes a lag in the response of the sensor to a temperature change. In the case of the remote sensor, this should not be a problem, since it is either a substrate transistor in the processor or a small package device, such as SOT-23, placed in close proximity to it.

The on-chip sensor, however, is often remote from the processor and only monitors the general ambient temperature around the package. In practice, the ADT7482 package is in electrical, and hence thermal, contact with a PCB and may also be in a forced airflow. How accurately the temperature of the board and/or the forced airflow reflects the temperature to be measured also affects the accuracy. Self-heating due to the power dissipated in the ADT7482 or the remote sensor causes the chip temperature of the device or remote sensor to rise

above ambient. However, the current forced through the remote sensor is so small that self-heating is negligible. In the case of the ADT7482, the worst-case condition occurs when the device is converting at 64 conversions per second while sinking the maximum current of 1 mA at the ALERT and THERM output. In this case, the total power dissipation in the device is about 4.5 mW. The thermal resistance,  $\theta_{JA}$ , of the MSOP-10 package is about 142°C/W.

## LAYOUT CONSIDERATIONS

Digital boards can be electrically noisy environments, and the ADT7482 is measuring very small voltages from the remote sensor, so care must be taken to minimize noise induced at the sensor inputs. Take the following precautions:

- Place the ADT7482 as close as possible to the remote sensing diode. Provided that the worst noise sources, that is, clock generators, data/address buses, and CRTs, are avoided, this distance can be 4 inches to 8 inches.
- Route the D+ and D- tracks close together, in parallel, with grounded guard tracks on each side. To minimize inductance and reduce noise pick-up, a 5 mil track width and spacing is recommended. Provide a ground plane under the tracks, if possible.



Figure 24. Typical Arrangement of Signal Tracks

- Try to minimize the number of copper/solder joints that can cause thermocouple effects. Where copper/solder joints are used, make sure that they are in both the D+ and D- path and at the same temperature.

- Thermocouple effects should not be a major problem as 1°C corresponds to about 200 mV, and thermocouple voltages are about 3 mV/°C of temperature difference. Unless there are two thermocouples with a big temperature differential between them, thermocouple voltages should be much less than 200 mV.
- Place a 0.1  $\mu$ F bypass capacitor close to the V<sub>DD</sub> pin. In extremely noisy environments, an input filter capacitor can be placed across D+ and D-, close to the ADT7482. This capacitance can effect the temperature measurement, so care must be taken to ensure that any capacitance seen at D+ and D- is a maximum of 1000 pF. This maximum value includes the filter capacitance, plus any cable or stray capacitance between the pins and the sensor diode.
- If the distance to the remote sensor is more than 8 inches, the use of twisted pair cable is recommended. A total of 6 feet to 12 feet is needed.
- For long distances (up to 100 feet), use shielded twisted pair, such as Belden No. 8451 microphone cable. Connect the twisted pair to D+ and D- and the shield to GND close to the ADT7482. Leave the remote end of the shield unconnected to avoid ground loops.

Because the measurement technique uses switched current sources, excessive cable or filter capacitance can affect the measurement. When using long cables, the filter capacitance can be reduced or removed.

## APPLICATION CIRCUIT

Figure 25 shows a typical application circuit for the ADT7482, using discrete sensor transistors. The pull-ups on SCLK, SDATA, and ALERT are required only if they are not already provided elsewhere in the system.

The SCLK pin and the SDATA pin of the ADT7482 can be interfaced directly to the SMBus of an I/O controller, such as the Intel® 820 chipset.





Figure 25. Typical Application Circuit

# ADT7482

## OUTLINE DIMENSIONS



COMPLIANT TO JEDEC STANDARDS MO-187-BA

Figure 26. 10-Lead Mini Small Outline Package (MSOP)

RM-10

Dimensions shown in millimeters

## ORDERING GUIDE

| Model                    | Temperature Range | Package Description | Package Option | Branding | SMBus Address |
|--------------------------|-------------------|---------------------|----------------|----------|---------------|
| ADT7482ARMZ <sup>1</sup> | −40°C to +125°C   | 10-Lead MSOP        | RM-10          | T0A      | 4C            |
| ADT7482ARMZ-REEL         | −40°C to +125°C   | 10-Lead MSOP        | RM-10          | T0A      | 4C            |
| ADT7482ARMZ-REEL7        | −40°C to +125°C   | 10-Lead MSOP        | RM-10          | T0A      | 4C            |

<sup>1</sup> Z = Pb-free part.